

Addendum

October 14, 2024 Questions/Answers

RFP 24-036 Commercial Grade Kitchen Renovation

Q1. What is the color/brand of the current flooring?

A1. Floor was replaced in 2021 with LVT. At that time, the price was estimated at \$4/sf. Please match existing flooring, if needed.

The 2021 RFP had the following specs.

- Flooring should be vinyl plank high-performance flooring, waterproof, with texture for slip proof safety, 8 mm thickness, and 20 ml. wear layer
- Flooring should be of commercial grade and have acoustical pad for noise reduction

Q2. What is the color/brand of the current paint?

A2. The brand is Sherwin Williams. Please match existing color, or this can be discussed as needed.

Q3. Will a grease trap be required with the new sink?

A3. No, a grease trap will not be required.


Q4. Will a backflow device be required with the new sink?

A4. No, a backflow device will not be required.

Q5. What are the changes to the cabinet/cupboard quantity?

A5. The bid should include all cabinets, drawers, and one set of cupboards. We are eliminating the cupboards above the stove and refrigerator.

- Eliminate the cupboards circled in red.
- Replace the cupboards circled in green.



Q6. Will permits be required?

A6. Depending on the scope of work, permits may be required. These will be the responsibility of the contractor.